

RYERSON ELEMENTARY			
30 MCCLELLAND AVE			
KEY :	TNR: TESTING NOT REQUIRED		
	DEP & EPA STANDARD LEAD LEVEL: < 15.000 PARTS PER BILLION		
	ND: NONE DETECTED BS: BELOW DEP / EPA STANI		
* REATEST 10/26/16	SP: NON POTABLEWATER (NOT FOR DRINKING) FOR HAND WASHING ONLY	TEST DATE : 9/23/16	
SAMPLE NUMBER	SAMPLE DESCRIPTION / LOCATION	FIRST DRAW TEST RESULTS	REMEDIAL ACTION NOTES
L6428037-1	MEDIA CENTER OFFICE	ND	BS
L6428037-2	CLASSROOM 21 SINK	3.800	TNR/BS
L6428037-3	MAIN OFFICE SINK	1.100	BS
L6428037-4	CLASSROOM 19 SINK	5.900	TNR/BS
L6428037-5	CLASSROOM 20 SINK	9.600	TNR/BS
L6428037-6	MAIN OFFICE BATHROOM SINK	ND	TNR/BS
L6428037-7	CLASSROOM 23 SINK	7.000	TNR/BS
L6428037-8	CAFETERIA FOUNTAIN	ND	BS
L6428037-9	CLASSROOM 19 SINK	4.400	TNR/BS
L6428037-10	CLASSROOM 22 SINK	<15 ppb	TNR/BS
L6428037-11	GYM FOUNTAIN	ND	BS
L6428037-12	MAIN ENT FOUNTAIN	ND	BS
L6428037-13	KITCHEN SINK RIGHT	ND	BS
L6428037-14	BOYS ROOM MAIN ENT SINK RIGHT	2.400	TNR/BS
L6428037-15	KITCHEN SINK ON ISLAND	1.700	BS
L6428037-16	KITCHEN SINK LEFT	ND	BS
L6428037-17	BOYS ROOM MAIN ENT SINK LEFT	3.200	TNR/BS
L6428037-18	GIRLS ROOM BACK SINK	ND	TNR/BS
L6428037-19	GIRLS ROOM MAIN ENT SINK RIGHT	2.000	TNR/BS
L6428037-20	GIRLS ROOM MAIN ENT SINK LEFT`	ND	TNR/BS
L6428037-21	SLOP SINK BY MAIN ENT	3.200	TNR/BS
L6428037-22	BOYS ROOM MAIN ENT STAFF SINK	6.900	TNR/BS
L6428037-23	CLASSROOM 8 FOUNTAIN	3.900	BS
L6428037-24	CLASSROOM 8 SINK	2.500	TNR/BS
L6428037-25	CLASSROOM 6 SINK	1.300	TNR/BS
L6428037-26	CLASSROOM 8 FOUNTAIN	ND	BS
L6428037-27	FOUNTAIN BY CLASSROOM 8	2.300	BS
L6428037-28	CLASSROOM 9 SINK	ND	TNR/BS
L6428037-29	NURSES OFFICE FOUNTAIN	ND	BS
L6428037-30	CLASSROOM 10 SINK	3.600	TNR/BS
L6428037-31	CLASSROOM 1 SINK	ND	TNR/BS
L6428037-32	WOMENS ROOM SINK RIGHT BY CLASSROOM 17	ND	TNR/BS
L6428037-33	CLASSROOM 5 SINK	2.100	TNR/BS
L6428037-34	FOUNTAIN NEXT TO CLASSROOM 17	ND	BS
L6428037-35	CLASSROOM 1 FOUNTAIN	1.900	BS
L6428037-36	CLASSROOM 7 SINK	1.600	TNR/BS

RYERSON ELEMENTARY			
30 MCCLELLAND AVE			
KEY :	TNR: TESTING NOT REQUIRED		
	DEP & EPA STANDARD LEAD LEVEL: < 15.000 PARTS PER BILLION		
	ND: NONE DETECTED BS: BELOW DEP / EPA STANDARD		
* REATEST 10/26/16	SP: NON POTABLEWATER (NOT FOR DRINKING) FOR HAND WASHING ONLY	TEST DATE : 9/23/16, 9/27/16	
SAMPLE NUMBER	SAMPLE DESCRIPTION / LOCATION	FIRST DRAW TEST RESULTS	REMEDIAL ACTION NOTES
L6428037-37	BOILER ROOM SINK	ND	TNR/BS
L6428037-38	CLASSROOM 4 SINK	2.300	TNR/BS
6525178-1	CLASSROOM 2 FOUNTAIN	* 2.800	BS
L6428037-40	CLASSROOM 17 FOUNTAIN	ND	BS
L6428037-41	NURSES OFFICE SINK	2.800	BS
L6428037-42	CLASSROOM 5 FOUNTAIN	ND	BS
L6428037-43	CLASSROOM 16 SINK	2.300	TNR/BS
L6428037-44	ART ROOM SINK 2	ND	TNR
L6428037-45	CUSTODIAN CLOSET SINK	2.300	TNR/BS
L6428037-46	CLASSROOM 2 SINK	1.900	TNR/BS
L6428037-47	MENS ROOM SINK LEFT BY CLASSROOM 17	>15 ppb	TNR/ SP
L6428037-48	ART ROOM SINK 3	2.600	TNR/BS
L6428037-49	TEACHERS ROOM SINK	ND	BS
L6428037-50	CLASSROOM 10 FOUNTAIN	2.900	BS
L6428037-51	CLASSROOM 15 SINK	2.300	TNR/BS
L6428037-52	ART ROOM SINK 1	1.400	TNR/BS
L6428037-53	CLASSROOM 24 SINK	ND	TNR/BS
L6428037-54	MENS ROOM SINK RIGHT BY CLASSROOM 17	<15 ppb	TNR/BS
L6428037-55	CLASSROOM 13 SINK	7.500	TNR/BS
L6428037-56	WOMENS ROOM SINK LEFT BY CLASSROOM 17	ND	TNR/BS
L6428037-57	CLASSROOM 25 SINK	ND	TNR/BS
L6428037-58	CLASSROOM 17 SINK	1.100	TNR/BS
L6428037-59	CLASSROOM 11 SINK	4.800	TNR/BS
L6525178-2	CLASSROOM 11 FOUNTAIN	* 5.800	BS
L6428037-61	CLASSROOM 12 SINK	5.300	TNR/BS
L6428037-62	CLASSROOM 3 SINK	2.000	TNR/BS
L6428037-63	CLASSROOM 13 FOUNTAIN	7.800	BS